

LIGHTNING EQUIPOTENTIAL BONDING

ISOLATING SPARK GAP

Product Type	Code	DC - Sparkover Voltage (V)	Max. Lightning Impulse Current 10 / 350 μ s I_{imp} (KA)	Max. Impulse Discharge Current 8 / 20 μ s I_{max} (KA)	Nominal Impulse Discharge Current 8 / 20 μ s I_n (KA)	EC - Type Examination Certificate	Class of Lightning Impulse Current Strength (EN50164-3)	Approvals
HGS100 EX	10 004	400 ~ 750	100	100	75	II 2G Ex mb II T6 II 2D Ex mb D 21 T80°C	H	FTZU 04 ATEX 0255X
HGS 100	10 005	400 ~ 750	100	100	75	...	...	...
HGS100 EB	10 009	400 ~ 750	100	100	75	...	...	...
HGS100 RW	10 002	300 ~ 500	100	150	75	...	...	...

Approvals: CE 

